

SUBJECT: **Location of Appliance Shutoff Valves**

EFFECTIVE DATE: October 25, 2010

INTERPRETATION NUMBER: ADM – 2.1212.4 (Formerly 2.1211.15)

SEE ALSO: 2006 UPC – Section 1212.4

INTERPRETATION SUMMARY

This section requires that appliance shutoffs are to be located in an accessible location within 6' of the appliance and in the same room or space. It is our interpretation that a valve located in a closet or space contiguous with and accessory to the room where the appliance is located is acceptable.